



**DISTRICT OF COLUMBIA DEPARTMENT OF MENTAL HEALTH  
 CONTRACTS AND PROCUREMENT ADMINISTRATION  
 64 NEW YORK AVENUE, NE 4<sup>TH</sup> FLOOR, WASHINGTON, DC 20002  
 PHONE: (202) 671-3174 \* FAX: (202) 671-3395**

November 3, 2010

**AMENDMENT ONE (1) RM-011-IFB-027-BY0-DJW for WATER FILTRATION SYSTEM for  
 SAINT ELIZABETHS HOSPITAL**

**TO ALL PROSPECTIVE BIDDERS:**

This Amendment is in two parts.

**PART I** Questions from Bidders and Answers from the Program

**PART II** Administrative Revisions and Additions to the Solicitation

**PART I**

| Question Number  | IFB Section | Question   |
|--|-------------|--|
| 1.   | N/A         | What is the pathway or routing for the electrical to the panelboard from the water filter? |
| <b>DMH RESPONSE:</b><br>The Contractor shall run the electric along the mezzanine and penetrate the slab to the electrical room below.   |             |  |
| Question Number  | IFB Section | Question   |
| 2.   | N/A         | Is there a restriction for when we can shut off the water?                                 |
| <b>DMH RESPONSE:</b><br>The final water connections shall be completed at night. The Contractor shall make every preparation for only one water supply disruption.                             |             |  |
| Question Number  | IFB Section | Question   |
| 3.   | N/A         | Where can a Contractor deliver its supplies and materials to?                              |
| <b>DMH RESPONSE:</b><br>All deliveries shall be coordinated with the Construction Manager (CM), the Contracting Officer Technical Representative (COTR) and shall be through the Loading Dock. |             |  |
| Question Number  | IFB Section | Question   |
| 4.   | N/A         | What is the location of Contractor parking?  |
| <b>DMH RESPONSE:</b><br>The Contractors shall park by the Gilbane Trailer and sign-in at the Solutions Center each day.  |             |  |

| Question Number   | IFB Section | Question   |
|---|-------------|--|
| 5.  | N/A         | P204 and P101 are the same sheet, please clarify.  |
| <b>DMH RESPONSE:</b>  |             |  |
| P204 may have been sent out. It is a duplicate of P101, therefore, it is not needed.  |             |  |
| Question Number   | IFB Section | Question   |
| 6.  | N/A         | Who is the contact for the Hospital's BMCS system? |
| <b>DMH RESPONSE:</b>  |             |  |
| The Hospital has a Honeywell BMCS System. Honeywell's contact is:<br>Joseph Coscia<br>Cell: (863)-222-2899<br>Fax: (973)-695-1629<br>Email: joseph.coscia@honeywell.com |             |  |

END OF PART 1


**PART II**

The above referenced IFB is hereby amended as follows:

**ALL OTHER TERMS AND CONDITIONS OF THE INVITATION FOR BID (IFB) REMAIN UNCHANGED.**

Only one copy of this amendment is being sent to prospective Offerors. Offerors shall sign below and attach a signed copy of this amendment to each Bid to be submitted to the place specified for receipt of Bids. Bids shall be mailed or delivered in accordance with the instructions provided in the original IFB. In the event your Bid has been previously deposited with the Department of Mental Health, Contracts and Procurement Administration (DMH/CPA), submit this signed Amendment in a sealed envelope, identified on the outside by the IFB number and submission date. This signed Amendment must be received by the DMH/CPA on or before **November 10, 2010 at 12:00 PM EST** the date and time for closing. **Failure to acknowledge receipt of Amendment One (1) for Solicitation Number RM-011-IFB-027-BY0-DJW may be cause for rejection of any Bid submitted in response to the subject IFB.**

Signed:

  
\_\_\_\_\_  
Samuel J. Feinberg, CPPD, CPPB  
Director, Contracts and Procurement  
Agency Chief Contracting Officer

November 3, 2010  
Date

Amendment Number One (1) is hereby acknowledged and is considered a part of the Bid for Solicitation Number **RM-011-IFB-027-BY0-DJW**.

\_\_\_\_\_  
Signature of Authorized Representative

\_\_\_\_\_  
Date

\_\_\_\_\_  
Title of Authorized Representative

\_\_\_\_\_  
Print or Type Name of Offeror

**END OF PART II**