



**DISTRICT OF COLUMBIA DEPARTMENT OF BEHAVIORAL HEALTH
CONTRACTS AND PROCUREMENT SERVICES
64 NEW YORK AVENUE, NE, 2ND FLOOR, WASHINGTON, DC 20002
PHONE: (202) 671-3171 ♦ FAX: (202) 671-3395**

January 15, 2015

**REQUEST FOR QUOTATION (RFQ)
SOLICITATION FOR CHEMICAL WATER TREATMENT SERVICES
AMENDMENT NUMBER TWO (2)
RM-15-RFQ-060-BY4-JM**

TO ALL PROSPECTIVE BIDDERS:

The above solicitation is hereby amended to reflect DBH's response to questions that were received from Prospective Bidders

QUESTIONS AND ANSWERS

Question No.	RFP Section	Question
1		Who is your current water treatment provider?
DBH RESPONSE: CPS does not provide this information. The requested information is available by FOIA Request		
Question No.	RFP Section	Question
2		What is the current value of the contract?
DBH RESPONSE: CPS does not provide this information. The requested information is available by FOIA Request		
Question No.	RFP Section	Question
3		Do you have the circulating pump GPM's available for each system, if so what are the numbers?
DBH RESPONSE: This Contract is to provide services to the Chemical Feed System only. However, the plant has the following circulating pumps: <u>FOR THE CHILL WATER</u> 6 pumps (# 1, 2, 3, 6 and 7) at 2100 GPM 2 pumps (# 4 and 5) at 3200 GPM		

FOR THE HEATING

3 pumps (# 9, 10 and 11) at 800 GPM

2 pumps (# 12 and 13) at 1700 GPM

Question No.	RFP Section	Question
4		In Section C.5/Page 14 you only list Chemical Pumps and Chemical Mixers, is there a control panel installed (for water treatment, if so what kind)? Do they closed loop systems have any chemical feed equipment (i.e. Bypass Feeder) if so what size?

DBH RESPONSE: There is a control panel installed for the cooling tower. It is a CASCADE Water Service - 3 Roytronic Pumps – 3/8” Feed lines. This is not a closed loop system.

Question No.	RFP Section	Question
5		Are there any water loss issues with any of the systems, if so how much?


DBH RESPONSE: There are no water loss issues with the systems.

ALL OTHER TERMS AND CONDITIONS OF THE REQUEST FOR QUOTE REMAIN UNCHANGED.

Only one copy of this Amendment is being sent to Prospective Bidders. Bidders shall sign below and attach a signed copy of this Amendment to each proposal to be submitted to the place specified for receipt of Quotes. Quotes shall be mailed or delivered in accordance with the instructions provided in the original RFQ Solicitation. In the event your proposal has been previously deposited with the Department of Behavioral Health, Contracts and Procurement Services (DBH/CPS), submit this signed Amendment in a sealed envelope, identified on the outside by the RFQ number and submission date. This signed Amendment must be received by the DBH/CPS no later than the date and time for closing.

Failure to acknowledge receipt of Amendment Two (2) for Solicitation Number RM-15-RFQ-060-BY4-JM may be cause for rejection of any Quote submitted in response to the subject RFQ Solicitation.

Signed:


 Samuel J. Feinberg, CRPO, CPPB
 Director, Contracts and Procurement
 Agency Chief Contracting Officer

Amendment Number Two (2) is hereby acknowledged and is considered a part of the Quote for Solicitation Number RM-15-RFQ-060-BY4-JM.

 Signature of Authorized Representative

 Date

 Title of Authorized Representative

 Print or Type Name of Offeror